

Town: BARTLETT

EPA Id: NH 0162300

System Name: ATTITASH WOODS CONDO ASSOC

Pop Served: 135

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300021	FLUORIDES	MCL VIOLATION	4.00000	3.50000000	01/16/2004	

EPA Id: NH 0168460

System Name: BEAR PEAK AT ATTITASH

Pop Served: 800

PWS Type: NON-TRANSIENT NON-COMMUNITY

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300005	FLUORIDES	MCL VIOLATION	4.00000	2.70000000	01/16/2004	
400003	COLIFORM (TOTAL COLIFORM RULE)	NON-ACUTE MCL VIOLATION /STANDARD		Present	12/01/2003	05/27/2004

EPA Id: NH 0162340

System Name: BEAR VILLAGE SOUTH

Pop Served: 30

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300014	FLUORIDES	MCL VIOLATION	4.00000	3.70000000	01/16/2004	

EPA Id: NH 0162220

System Name: CHRISTMAS MOUNTAIN CONDOS

Pop Served: 203

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300011	FLUORIDES	MCL VIOLATION	4.00000	2.40000000	01/16/2004	

EPA Id: NH 0162190

System Name: CRAWFORD HILLS

Pop Served: 118

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400004	COLIFORM (TOTAL COLIFORM RULE)	NON-ACUTE MCL VIOLATION /STANDARD		Present	11/14/2003	05/05/2004

EPA Id: NH 0162350

System Name: GOODRICH PROPERTY OWNERS ASSOC

Pop Served: 175

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300018	FLUORIDES	MCL VIOLATION	4.00000	2.60000000	01/16/2004	

EPA Id: NH 0162070

System Name: LINDERHOF GOLF COURSE

Pop Served: 298

PWS Type: COMMUNITY SYSTEM

Town: BARTLETT**EPA Id: NH 0162070****System Name: LINDERHOF GOLF COURSE****Pop Served: 298****PWS Type: COMMUNITY SYSTEM**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300007	FLUORIDES	MCL VIOLATION	4.00000	2.10000000	01/12/2004	

EPA Id: NH 0162090**System Name: LINDERHOF MOUNTAINSIDE****Pop Served: 663****PWS Type: COMMUNITY SYSTEM**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300022	COLIFORM (TOTAL COLIFORM RULE)	NON-ACUTE MCL VIOLATION /STANDARD		Present	08/07/2003	03/04/2004
300023	COLIFORM (TOTAL COLIFORM RULE)	NON-ACUTE MCL VIOLATION /STANDARD		Present	09/26/2003	03/04/2004
300024	FLUORIDES	MCL VIOLATION	4.00000	3.00000000	01/12/2004	

EPA Id: NH 0162210**System Name: MOUNTAINSIDE AT ATTITASH****Pop Served: 167****PWS Type: COMMUNITY SYSTEM**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300004	FLUORIDES	MCL VIOLATION	4.00000	3.40000000	01/16/2004	

EPA Id: NH 0167080**System Name: MT ATTITASH SKI/AQUABOGGAN****Pop Served: 1000****PWS Type: NON-COMMUNITY TRANSIENT**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300002	COLIFORM (TOTAL COLIFORM RULE)	NON-ACUTE MCL VIOLATION /STANDARD		Present	02/13/2003	07/16/2004

EPA Id: NH 0162270**System Name: NORDIC VILLAGE****Pop Served: 315****PWS Type: COMMUNITY SYSTEM**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300004	FLUORIDES	MCL VIOLATION	4.00000	3.10000000	01/16/2003	

EPA Id: NH 0162050**System Name: NORTH LEDGE****Pop Served: 103****PWS Type: COMMUNITY SYSTEM**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300024	FLUORIDES	MCL VIOLATION	4.00000	2.60000000	01/12/2004	

EPA Id: NH 0162230**System Name: PARTRIDGE WOODS CONDOMINIUMS****Pop Served: 120**

Town: BARTLETT

EPA Id: NH 0162230

System Name: PARTRIDGE WOODS CONDOMINIUMS

Pop Served: 120

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300016	FLUORIDES	MCL VIOLATION	4.00000	3.30000000	01/16/2004	

EPA Id: NH 0162100

System Name: RIVERSBEND

Pop Served: 48

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400011	FLUORIDES	MCL VIOLATION	4.00000	4.36000000	10/31/2003	

EPA Id: NH 0162140

System Name: RIVERSIDE COBB FARM HO

Pop Served: 63

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300004	FLUORIDES	MCL VIOLATION	4.00000	2.90000000	01/13/2004	

EPA Id: NH 0162290

System Name: ROCKY RIVER RESORT

Pop Served: 100

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400005	FLUORIDES	MCL VIOLATION	4.00000	4.70000000	11/21/2003	

EPA Id: NH 0162130

System Name: ROLLING RIDGE

Pop Served: 83

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300012	FLUORIDES	MCL VIOLATION	4.00000	3.80000000	01/12/2004	
300013	BERYLLIUM	MCL VIOLATION	0.00400	0.01100000	02/19/2004	

EPA Id: NH 0162020

System Name: SACO RIDGE WATER INC

Pop Served: 80

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300006	FLUORIDES	MCL VIOLATION	4.00000	3.20000000	01/22/2004	

EPA Id: NH 0162410

System Name: STILLINGS GRANT

Pop Served: 83

PWS Type: COMMUNITY SYSTEM

Town: BARTLETT

EPA Id: NH 0162410

System Name: STILLINGS GRANT

Pop Served: 83

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300001	FLUORIDES	MCL VIOLATION	4.00000	2.70000000	01/16/2004	

EPA Id: NH 0162240

System Name: THE SEASONS AT ATTITASH

Pop Served: 440

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300018	FLUORIDES	MCL VIOLATION	4.00000	3.90000000	01/16/2004	

EPA Id: NH 0162200

System Name: TOP NOTCH CONDOMINIUMS ASSOC

Pop Served: 163

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300013	FLUORIDES	MCL VIOLATION	4.00000	2.10000000	01/13/2004	

EPA Id: NH 0162310

System Name: WHISPERING BROOK

Pop Served: 30

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
300001	FLUORIDES	MCL VIOLATION	4.00000	3.30000000	01/16/2004	

Description of Data Reported**PWS: Public Water System**

Town: Town, city or unincorporated place - political boundary in which the system is located.

EPA Id: Also known as PWS Id. State and Federal number assigned to track PWS.

System Name: Legal name of PWS.

Pop Served: The population served by PWS.

PWS Type: Type of PWS based on Federal Definition.

Community: Residential system capable of serving at least 25 residents.

Non-Community Non-Transient: Non-residential system capable of serving at least 25 of the same people 6 months a year.

Non-Community Transient: A system capable of serving water to at least 25 people 60 days a year.

Viol Id: The Federal Fiscal Year plus the violation identifier assigned by Environmental Services.

Contaminant: The contaminant and/or rule of which the PWS is in violation.

Violation Description: The type of violation.

Awareness: Date the state became aware of the MCL or TT violation.

MCL (Maximum Contaminant Level): The highest amount of a contaminant that the EPA allows in drinking water. MCLs are defined in milligrams per liter (Mg/l) (parts per million) unless otherwise specified.

Result: Chemical Monitoring (Phase I, II, IIB and V) Rules: The analytical result(s) that caused the MCL violation.

Bacteria (Total Coliform) Rule: PRESENT indicates an MCL violation. ie., coliform is present.

Lead and Copper Rule and Surface Water Treatment Rule: TT (Treatment Technique) Violation or failure to meet operational and/or system requirements under the rule.

Comp Achved: The date the PWS returned to compliance for the violation.

* The violations listed are based on both Env-WS300 "NH Drinking Water Rules" and 40 CFR Part 141-143 "National Primary Drinking Water Regulations, Secondary Drinking Water Regulations"

--- END OF REPORT ---